

UNIVERSITÀ DEGLI STUDI FIRENZE DIDA DIPARTIMENTO DI ARCHITETTURA

BRIEF | Comfort Modeling & Environmental Users' Requirements





G. RIDOLFI





Architecture

Environmental Design Class

- 01. **BRIEF** Program & Environmental Report
- 02. CONCEPT Architectural Mass & Lay-out Optioneering
- 03. SCHEME Architectural Proposal
- 04. **DETAIL** Envelope Design & Conceptual Prototype
- 05. **FINAL** Project Communication



PROGRAM | Comfort Modeling & Environmental Users' Requirements







BRIEF | Program & Environmental Report

1.1. Project Mission & Space Program

- 1.2. Comfort Modeling & Environmental Users' Requirements
- **1.3. Climate based Design strategies**
- 1.4. Site Assessment







MAILAB Multimedia Architecture Interaction

PROGRAM | Comfort Modeling & Environmental Users' Requirements





part



BRIEF | Comfort Modeling & Environmental Users' Requirements





Architecture

Interaction

PROGRAM | Comfort Modeling & Environmental Users' Requirements









PROGRAM | Comfort Modeling & Environmental Users' Requirements

Standardized Comfort By Building Regulation Indoor Design Conditions³

Type of Area General Office ADP Rooms Corridors **Building Lobbies** Toilets Locker Rooms **Electrical Closets** Mech. Spaces Elec. Switchgear Elevator Mach. Room Emerg. Gen. Room **Transformer Vaults** Stairwells Comm./Tel. Frame Room Storage Room Conference Room Auditorium Kitchen Dining Cafeteria Courtrooms

*Requires humidification in the winter.

Notes:

- 1 Temperatures are degrees Celsius (Fahrenheit), to be maintained at +/-1 °C (+/-2 °F).
- 2 Relative humidity is minimum permissible, stated in percent. Maximum permissible relative humidity is 60 percent in conditioned areas.
- 3 Dry bulb and relative humidity are to be maintained 150 mm (6 inches) to 1800 mm (6 feet) above the floor.
- 4 Relative humidity should be maintained at +/-5 percent in ADP spaces.
- 5 Maximum temperature. Space to be mechanically cooled if necessary.
- 6 Room must not exceed temperature with generator running.
- 7 Must comply with EIA/TIA Standard 569.
- 8 Minimum temperature in the building must be 13 °C (55 °F) even when unoccupied.
- recorder),
- 10 System shall be designed for process cooling. Cooling system shall be a dedicated independent system.
- 11 Provide independent temperature control.
- 12 Minimum relative humidity requirements may be omitted in moderate southern climate zones upon approval of local GSA representatives.

Summer DB ¹	RH ²	Winter DB ¹	RH ²
24 (75)		22 (72)	
22 (72)	45 ⁴	22 (72)	
24 (75)		22 (72)	
24 (75)		22 (72)	
24 (75)		22 (72)	
26 (78)		21 (70)	
26 (78)		13 (55)	
35 (95) ⁵		13 (55) ⁸	
35 (95) ⁵		13 (55)	
26 (78) ⁵		13 (55)	
40 (104) ⁶		18 (65)	
40 (104) ⁵			
(none)		18 (65)	
24 (75)	45	22 (72)	30 ¹²
30 (85)		18 (65)	
24 (75)		22 (72)	
24 (75)		22 (72)	
24 (75)		22 (72)	
24 (75)		22 (72)	
24 (75)		22 (72)	
24 (75)		22 (72)	454*

9 Confirm equipment manufacturer's requirements as more stringent. Provide in-room display and monitor device (such as wall mounted temperature and humidity chart



MAILAB

Multimedia Architecture Interaction

Standardized Comfort By Building Regulation

Activity	Illumination (lux, lumen/m ²)
Public areas with dark surroundings	20 - 50
Simple orientation for short visits	50 - 100
Working areas where visual tasks are only occasionally performed	100 - 150
Warehouses, Homes, Theaters, Archives	150
Easy Office Work, Classes	250
Normal Office Work, PC Work, Study Library, Groceries, Show Rooms, Laboratories	500
Supermarkets, Mechanical Workshops, Office Landscapes	750
Normal Drawing Work, Detailed Mechanical Workshops, Operation Theatres	1,000
Detailed Drawing Work, Very Detailed Mechanical Works	1500 - 2000
Performance of visual tasks of low contrast and very small size for prolonged periods of time	2000 - 5000
Performance of very prolonged and exacting visual tasks	5000 - 10000
erformance of very special visual tasks of extremely low contrast and small size	10000 - 20000





MAILAB

Multimedia Architecture Interaction

Standardized Comfort By Building Regulation

Source IESNA, 9th Edition Lighting Handbook, Reference and Applications, Chapter 10

I. INTERIOR		Ve	ry In	npor	tant		Im	porta	ant		So	mev	vhat	t im	porta	ant		Bla	ink =	= No	ot in	npoi	tan	t or not applicable
LOCATIONS AND TASKS							2														-	-		
	Annearance of Snace and Luminairee	Color Appearance (and Color Contrast)	Daylighting Integration and Control	Direct Glare	Flicker (and Strobe)	Light Distribution on Surfaces	Light Distribution on Task Plane (Uniformit	Luminances of Room Surfaces	Modeling of Faces or Objects	Point(s) of Interest	Reflected Glare	Shadows	Source/Task/Eye Geometry	Sparkle/Desirable Reflected Highlights	Surface Characteristics	System Control and Flexibility	Special Considerations	Notes on Special Considerations	Illuminance (Horizontal)	Category or Value (lux)	Illuminance (Vertical)	Category or Value (lux)	Notes on Illuminance - see end of section	Reference Chapter(s)
Reading (16)																								Ch. 11, 12
			1.00			_										1				10.4	_		_	
Copied tasks			_														-	_						
Microfiche reader					- 1							_			1					A		A		
Photograph, moderate detail	_	_													10	r			-	E		40	_	
Thermal copy, poor	_																		-	F	- 4			
Photocopies		_												1					-	D				
Photocopies, 3 rd generation		_																		E	100			
Data processing tasks													- 41	1										
VDT screens		_												r					F	A		Α		
Impact printer								_	_	_	_	_								-				
good ribbon	- 13																			D				
2 ^{re} carbon and greater	_	1																		E				
ink jet/laser printer			-				-	-	-	_										D				
keyboard reading	_						ſ	-												D				
Machine rooms		- 1						-				- 1												
Active operations				_			-	_										10		D		_		
l ape storage	_	_		<u> </u>													-		-	D		в		
Machine area	_	_	- 1									- 1								C		0		
Equipment service	_	_	_									- 1					1	<i>r</i> -	-	느		С		
I nermal print	_	_			<u> </u>		ſ	-				- 1				-	-	-	r	E				
Handwritten tasks	_	_		- 1				-								- 4				D				
#2 pencil and softer leads	_			- 1												1			-	-				
#3 pencil							-						-			100	-		-	E				
#4 pencil and harder leads																								l
Ealt tip pop					- 1										1	1			-					
Handwritten eerben eenv		+				1																		ł
White boards			1																T			P		ł
Chalk boards	_							-																
Drinted tasks	_		1				I	Г																l
6-point type		+	-									I								F				l
8- and 10-point type		+	+				-																	
Glossy magazines						<u> </u>														D				
Maps			<u> </u>																	F			<u> </u>	
Newsprint							-																	
Typed originals							-						-							D				
Telephone books		+	1																	E				
			1																	_				·







Multimedia Architecture Interaction

Standardized Comfort By Building Regulation

IES ILLUMINANCE CATEGORIES and	VALUES	- for GENERIC INDO	OOR ACTIVITIES
ACTIVITY	CATEGOR	Y LUX	FOOTCANDLES
Public spaces with dark surroundings	A	20-30-50	2-3-5
Simple orientation for short temporary visits	в	50-75-100	5-7.5-10
Working spaces where visual tasks are only occasionally performed	с	100-150-200	10-15-20
Performance of visual tasks of high contrast or large size	D	200-300-500	20-30-50
Performance of visual tasks of medium contrast or small size	Е	500-750-1000	50-75-100
Performance of visual tasks of low contrast or very sm size	F	1000-1500-2000	100-150-200
Performance of visual tasks of low contrast or very sm size over a prolonged period	G	2000-3000-5000	200-300-500
Performance of very prolonged and exacting visual tasks	н	5000-7500-10000	5 <mark>00-</mark> 750-1000
Performance of very special visual tasks of extremely low contrast	I	10000-15000-20000	1000-1500-2000
A-C for illuminances over a lar D-F for localized tasks G-I for extremely difficult vis	rge area sual tas	(ie lobby space) ks	





PROGRAM | Mission, Branding, and Space program



Adaptive Comfort

The thermohygrometric aspect







Multimedia Architecture nteractio

Thermal Adaptive Comfort. Human Body Behavior



DIFFERENT HUMAN THERMAL ZONES





Architecture

Interaction

Thermal Adaptive Comfort. Human Body Behavior

<u>Thermal comfort= f (TEMPERATURE, WIND, HUMIDITY, METABOLIC RATE, DRESSING RATE)</u>



PROGRAM | Mission, Branding, and Space program

36°C

37°C

 temperature of the extremeties close to the body core temperature

sweat evaporation

vascular dilatation

comfortable - all OK

vascular constriction

on feet and hands

muscle contraction

body core temp: -2°C





Architecture Interaction

Thermal Adaptive Comfort. Human Body Behavior







Architecture

Interaction

Thermal Adaptive Comfort. Human Body Behavior









PROGRAM | Mission, Branding, and Space program

Thermal Adaptive Comfort. Human Body Behavior





The body exchanges:

·62% of this heat via radiation

- ·15% by evaporation
- ·10% by convection
- ·10% by respiration
- \cdot 3% by conduction

http://www2.ecospecifier.org/







Adaptive Comfort. Thermohygrometric factors

RECOGNIZING ENERGY FORMS

FORMS of ENERGY EXCHANGE



ENVIRONMENTAL DESIGN prof. arch. Giuseppe Ridolfi









PROGRAM | Mission, Branding, and Space program

Adaptive Comfort. Thermohygrometric factors

Environmental Temperature

Relatively small changes in mean radiant temperature have a far greater effect than similar changes in air temperatures (Ballinger 1992). This gives rise to the importance of recognising the overall Environmental Temperature [T(env)], as opposed to just the dry bulb temperature.

2/3 Mean radiant surface temperature + 1/3 Air temperature T(env) =



Radiant heating systems compensate a lower air temperature with a higher radiant temperature, while air heating systems compensate a lower radiant temperature with a higher air temperature. The operative temperature -- a weighted average of both -- can be the same. Source: Radiant Heating & Cooling Handbook, Richard Watson, 2008.











Adaptive Comfort. Effective Temperature and Thermohygrometric factors

Thermal comfort= f (TEMPERATURE, WIND, HUMIDITY)







Interaction

PROGRAM | Mission, Branding, and Space program

Adaptive Comfort. Effective Temperature and Thermohygrometric factors

HUMIDITY AGENT : COOLING vs HEATING A GENERAL ESTIMATION METHOD BASED ON EFFECTIVE (Apparent) TEMPERATURE

4.5

A 24-hour period set of data from a weather file shows the interaction of the dry bulb temperature, the relative humidity, the direct solar, diffuse solar, wind speed and cloud cover. Note the inverse relationship of temperature and humidity; direct and diffuse solar irradiation; and the inconsistent relationship between cloud cover and direct solar.

Source: Autodesk Ecotect Suite output of EnergyPlus weather data. Courtesy of Callison.



Inverse relationship between Temperature and Humidity







Adaptive Comfort. Effective Temperature and Thermohygrometric factors

HUMIDITY AGENT : COOLING vs HEATING A GENERAL ESTIMATION METHOD BASED ON APPARENT TEMPERATURE



PROGRAM | Mission, Branding, and Space program

The **AT** is defined as the temperature, at the reference humidity level, producing the same amount of discomfort as that experienced under the current ambient temperature and humidity. Basically the AT is an adjustment to the *ambient temperature* (T) based

on the level of humidity.

	25%	30%	35%	40%	45%	50%	55%	60%	65%	70%	75%	80%	85%	90%	95%	100%
42°	48	50	52						66		71	73	75	77	80	82
41°	46	48	51	53	55	\$7	59		64			70	72	74	76	79
40°	45	47	49	51	53	55	57		61		65	67	69	71	73	75
350	43	45	47	49	51	53	55	57	59	61					70	72
38°	42	44	45	47	49	51	53	55			60	62	84		67	69
37°	40	42	44	45	47	49	51	52	54				61	63	65	86
36°	39	42	42	44	45	47	49	50	52	-54	55	57	59	60	62	63
35°	37	39	40	42	44	45	47	48	50	51	53	- 54		58	59	61
34°	36	37	39	40	42	43	45	46	48	49	51	52	54	55	57	58
33°	34	36	37	35	40	41	43	44	46	47	48	50	51	53	54	55
32°	33	34	36	37	28	40	41	42	44	45	46	48	49	50	52	53
31°	32	33	34	35	37	38	39	40	42	43	44	45	47	48	49	50
30°	30	32	33	34	35	36	37	39	40	41	42	43	45	46	47	48
29°	29	30	31	32	33	35	26	37	38	39	40	41	42	43	45	46
28°	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43
27°	27	27	28	29	30	31	32	35	34	35	36	37	38	39	40	41
26°	26	26	27	28	29	30	31	32	33	34	34	35	36	37	38	39
25°	25	25	26	27	27	28	29	30	31	32	33	34	34	35	36	37
240	24	24	24	25	26	27	28	28	29	30	31	32	33	33	34	35
23°	23	23	23	24	25	25	26	27	28	28	29	30	31	32	32	33
22°	22	22	22	22	23	24	20	25	20	27	27	28	29	30	30	31
Fino a 29 C° Nessun disagio																
Da 30) a 34 (C° Se	ensazio	ne di d	lisagio											
Da 35	a 39 (° In	tenso	disagio	. Prude	enza: li	mitare	le attiv	rità fisic	he più	pesan	ti				

Da 40 a 45 C° Forte sensazione di malessere. Pericolo: evitare gli sforzi

Da 46 a 53 C^o Pericolo grave: interrompere tutte le attività fisiche

Pericolo di morte: colpo di calore imminente





MAILAB Multimedia Architecture Interaction

Adaptive Comfort. Effective Temperature and Thermohygrometric factors

HUMIDITY AGENT : COOLING vs HEATING A GENERAL ESTIMATION METHOD BASED ON APPARENT TEMPERATURE

39

37

HUMIDEX- PERCEIVED TEMPERATURE AND DISCOMFORT INDEX (range 20°C-34°C)

	25%	30%	6 35%	40%	45%	50%	55%	60%	65%	70%	75%	80%	85%
42°	48	50	52		57	59			66		71	73	
41°	46	48	51	53	55		59					70	72
40°	45	47	49	51	53	55	57						69
39°	43	45	47	49	51	53	55	57					
38°	42	44	45	47	49	51	53						
37°	40	42	44	45	47	49	51	52	54				61
36°	39	40	42	44	45	47	49	50	52	-54	55		
35°	37	39	40	42	44	45	47	48	50	51	53	54	
34°	36	37	39	40	42	43	45	46	48	49	51	52	54
33°	34	36	37	39	40	41	43	44	46	47	48	50	51
32°	33	34	36	37	38	40	41	42	44	45	46	48	49
31°	32	33	34	35	37	38	39	40	42	43	44	45	47
30°	30	32	33	34	35	36	37	39	40	41	42	43	45
29°	29	30	31	32	33	35	36	37	38	39	40	41	42
28°	28	29	30	31	32	33	34	35	36	37	38	39	40
27°	27	27	28	29	30	31	32	33	34	35	36	37	38
26°	26	26	27	28	29	30	31	32	33	34	34	35	36
25°	25	25	26	27	27	28	29	30	31	32	33	34	34
24°	24	24	24	25	26	27	28	28	29	30	31	32	33
23°	23	23	23	24	25	25	26	27	28	28	29	30	31
22°	22	22	22	22	23	24	25	25	26	27	27	28	29
Fino a	129 C°		Nessun (disagio									
Da 30) a 34 (0	Sensazio	ne di c	lisagio								
Da 35	a 39 0	· ·	Intenso	disagio	. Prude	enza: li	mitare	le attiv	ità fisic	the più	pesan	ti	

Interiso disagio. Prudenza: inflidire le activita fisicile più pesatiu Da 40 a 45 C° Forte sensazione di malessere. Pericolo: evitare gli sforzi

Pericolo grave: interrompere tutte le attività fisiche Da 46 a 53 C°

Pericolo di morte: colpo di calore imminente

PROGRAM | Mission, Branding, and Space program

HUMIDITY & AIR QUALITY GUIDE 90% 95% 100% Decreases in bar width indicates decrease in effect Optimum zone Bacteria Viruses Fungi Mites 53 Respiratory Infections 50 48 **Allergic Rhinitis** and Asthma 45 46 42 43 Chemical 40 Interactions 41 38 39 Ozone 36 37 Production 34 35 32 33 40 10 20 30 50 60 70 Insufficient data above 50 per cent R.H. Per Cent Relative Humidity 31 30 -00

OPTIMUM INDOOR RELATIVE





Adaptive Comfort. Effective Temperature and Thermohygrometric factors

HUMIDITY AGENT : COOLING vs HEATING A GENERAL ESTIMATION METHOD BASED ON APPARENT TEMPERATURE



PROGRAM | Mission, Branding, and Space program



HUMIDEX- PERCEIVED TEMPERATURE AND DISCOMFORT INDEX (range 20°C-55°C)



PROGRAM | Mission, Branding, and Space program

Project Mission. Goals and Philosophy



STUDIE UNIVERSITÀ DEGLI STUDI FIRENZE DIDA DIPARTIMENTO DI ARCHITETTURA

MAILAB Multimedia Architecture

Interaction

Project Mission. Goals and Philosophy IDENTIFYING THE COMFORT PERIOD







MAILAB

Multimedia

Architecture Interaction

Project Mission. Goals and Philosophy IDENTIFYING THE COMFORT PERIOD





università degli studi FIRENZE DIDA DIPARTIMENTO DI ARCHITETTURA

Interaction

MAILAB Multimedia Architecture

PROGRAM | Mission, Branding, and Space program

period to be cooled



MAILAB

Multimedia Architecture Interaction

OPTIMUM INDOOR RELATIVE HUMIDITY & AIR QUALITY GUIDE



Project Mission. Goals and Philosophy IDENTIFYING THE COMFORT PERIOD



PROGRAM | Mission, Branding, and Space program



Multimedia Architecture Interaction

UNIVERSITÀ Degli studi FIRENZE

Scuola di Architettura





Adaptive Comfort. Effective Temperature and Thermohygrometric factors

WIND AGENT : A GENERAL ESTIMATION METHOD BASED ON APPARENT TEMPERATURE

	Wind Speed	(mph)	IEIVIPEKA	IURE (App	arent iem	perature)
Temp (°C)	10	20	30	40	50	60
20	17	15	14	13	12	11
15	12	9	7	6	5	4
10	7	3	1	0	-2	-3
5	2	-3	-5	-7	-9	-10
0	-4	-9	-11	-14	-16	-17
-5	-9	-15	-18	-21	-23	-24
-10	-15	-21	-25	-28	-30	-32
-15	-21	-27	-32	-35	-37	-39
-20	-27	-33	-38	-42	-45	-47
		Significant	Severe	Extreme		

Wind chill equivalent temperatures from Steadman





Adaptive Comfort. Effective Temperature and Thermohygrometric factors

WIND AGENT : A GENERAL ESTIMATION METHOD BASED ON <u>APPARENT TEMPERATURE</u>

	Apparent temperature (AT) as a Wind Chill - after Steadman 1994 Temperature (°C)																									
												Tem	perat	ure (°C)											
	-5	- 4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
U 2	-8 -9	-7	-6 -6	-5	-4 -4	3	-2	-1 -1	1	2	3	4	5	6 6	8	9 8	1U 10	11 11	12	14	15	16 16	17	19 18	20 20	21
4	-9	-8	-7	-6	-5	-4	-2	-1	Ű	i	2	3	4	6	7	8	9	10	12	13	14	15	17	18	19	21
6	-9	-8	-7	-6	-5	-4	-3	-2	-1	1	2	3	4	5	6	8	9	10	11	12	14	15	16	18	19	20
8 10	-10	-9	-8		-0 -6	-4	-3	-2	-1	0		2	4	9 4	ь 6	7	8	9	10	12	13	10	16	17	19	20
12	-11	-9	-8	-7	-6	-5	-4	-3	-2	-1	1	2	3	4	5	6	8	9	10	11	13	14	15	16	18	19
14 16	-11	-10	-9 -9	-8	- 14	5 6	-4	-3	2	-1	U	1	2	4	5 //	6 6	7	8	1U 0	11 11	12	13	15 17	16 16	17	19
18	-12	-11	-10	-8	-7	-6	-5	-4	-3	-2	-1	1	2	3	4	5	6	8	9	10	11	13	14	15	17	18
20	-12	-11	-10	-9	-8	-7	-6 6	-4	-3	-2	-1	0	1	2	4	5	6	7	9	10	11 4 4	12	14	15 15	16 16	18
22	-13	-12	-11	-9	-0 -9	-7	-0	-0	-4	-3	-2	-1	1	2	3	4	5	6	8	9	10	12	13	10	15	17
26	-13	-12	-11	-10	-9	-8	-7	-6	-4	-3	-2	-1	0	1	2	4	5	6	7	9	10	11	12	14	15	16
- 28 30	-14	-13	-12 -12	-10	-9 -10	-8 -9	- 17		-5	-4	-3	-1	-1		2	3	5	6 5	7	8	9 9	11	12 12	13 13	15 14	16 16
32	-14	-13	-12	-11	-10	-9	-8	-7	-6	-4	-3	-2	-1	Ó	1	3	4	5	6	Ť	9	10	11	13	14	15
34 วด	-15	-14	-13	-12	-10	-9 10	-8	-7	6- a	-5	-4	-3	-1	0	ी - न	2	3	5	6 6	7	8	10	11 10	12	13	15
38	-16	-15	-13	-12	-11	-10	-9	-8	7	-6	-5	-3	-2	-1	0 0	1	3	4	5	6	8	9	10	11	13	14
40	-16	-15	-14	-13	-12	-11	-9	-8	-7	-6	-5	-4	-3	-1	0	1	2	3	5	6	7	8	10	11	12	14
4Z 44	-10	-15	-14	-13	-12	-11	-10	-9	-8	-0	-0 -6	-4	-3	-2	-1		1	3 3	4 4	5	6	8	9 9	10 10	12	13
46	-17	-16	-15	-14	-13	-12	-11	-9	-8	-7	-6	-5	-4	-3	-1	Ō	1	2	3	5	6	Ž	9	10	11	13
48 50	-18	-16	-15	-14	-13 -14	-12 -12	-11	-10	-9 -9	-8	-6 -7	-5 -6	-4 -5	-3	12	-1	1	2	3	4 4	6 5	6	8	y q	11 10	12
52	-18	-17	-16	-15	-14	-13	-12	-11	-10	-8	-7	-6	-5	-4	-3	-1	Ŭ	1	2	4	5	6	Ť	9	10	11
54 66	-19	-18 40	-17	-15 4 e	-14	-13	-12	-11	-10	-9	-8	-6	-5 6	-4	-3	-2	-1	1	2	3	4	6	7	8	10	11
58	-20	-18	-17	-16	-15	-14	-13	-12	-11	-10	-8	7	-6	-5	-4	3	-1	0	1	2	4	5	6	8	9	10
60	-20	-19	-18	-17	-16	-14	-13	-12	-11	-10	-9	-8	-6	-5	-4	-3	-2	-1	1	2	3	5	6	7	8	10
- 64	-20	-19	-18 -19	-17	-10	-15	-14	-13 -13	-12	-10	-9	-8	-7	-6	-0 -5	-3	-2	-1	0	1	3 2	4 4	5	6	8	9 9
66	-21	-20	-19	-18	-17	-16	-14	-13	-12	-11	-10	-9	-8	-6	-5	-4	-3	-2	Ō	1	2	3	5	6	Ž	9
- 68 70	-21 -22	-20	-19 -20-	-18 -19_	-17	-16 -16	-15 -15	-14	-13	-11	-10 -11	-9 -10	-8 -8	-7	-6 -6	-4	-3 -4	-2	-1 -1	0 0	2	3	4 4	6 5	7 6	8 8
72	-22	-21	-20	-19	-18	-17	-16	-15	-13	-12	-11	-10	-9	-8	-6	-5	-4	-3	-2	0	1	2	3	5	6	7
74	-23	-22	-20	-19	-18	-17	-16	-15	-14	-13	-12	-10	-9	-8	-7	-6 e	-4 E	-3	-2	-1	1	2	3	4	6	7
70 78	-23 - <u>23</u>	-22 -22	-21 -21	-20 - <u>20</u>	-19 - <u>19</u>	-18 - <u>18</u>	-16 - <u>17</u>	-15 - <u>16</u>	-14	-13	-12	-11	-10	-8 -9	-7 -8	-0 -6	-0 -5	-4	-2 -3	-2	0	1	3 2	4 4	о 5	/ 6
80	-24	-23	-22	-21	-19	-18	-17	-16	-15	-14	-13	-12	-10	-9	-8	-7	-6	-4	-3	-2	-1	1	2	3	5	6
				A	opare	ent te	mpe	ratur	e wit	h no	radia	tiona	al hea	ting	and i	relativ	/e hu	midit	:y fix	ed at	70%	6				

S Afind

Formula from Norms of apparent temperature in Australia, Aust. Met. Mag, Vol 43, 1994, 1-16.





MAILAB Multimedia Architecture Interaction

Adaptive Comfort. Effective Temperature and Thermohygrometric factors

WIND AGENT : A GENERAL ESTIMATION METHOD BASED ON APPARENT TEMPERATURE

						- 1		Air T	emper	ature	(Celsiu	IS)	1		_			
		0	-1	-2	-3	4	-5	-10	-15	-20	-25	-30	-35	-40	-45	-50	-55	-60
	6	-2	-3	4	-5	-1	-8	-14	-19	-25	-31	-37	-42	-48	154	-50	-65	-74
	8	-3	- 4	-5	-6	-7	-9	-14	-20	-26	-32	-38	-44					
	10	-3	-5	-6	-7	-8	-9	-15	-21	-27	-33	-39	-45					
	15	4	-6	-7	-8	.9	-11	-17	-23	-29	-35	-41						
	20	-5	-7	-8	-9	-10	-12	-18	-24	-30	-37	-43						
	25	-6	-7	-8	-10	-11	-12	-19	-25	-32	-38	-44						
	30	-6	-8	-9	-10	-12	-13	-20	-26	-33	-39							
Ē	35	-7	-8	-10	-11	-12	-14	-20	-27	-33	-10							
5	40	-7	-9	-10	-11	-13	-14	-21	-27	-34	-41							
ž	45	-8	-9	-10	-12	-13	-15	-21	-28	-35	-42							
Ŧ	50	-8	-10	-11	-12	-14	-15	-22	-29	-35	-42							
ě	55	-8	-10	-11	-13	-14	-15	-22	-29	-36	-43							
ă	60	-9	-10	-12	-13	-14	-16	-23	-30	-36	-43							
S	65	-9	-10	-12	-13	-15	-16	-23	-30	-37	-44					-79		
2	70	-9	-11	-12	-14	-15	-16	-23	-30	-37	-44							
5	75	-10	-11	-12	-14	-15	-17	-24	-31	-38	-45							
-	80	-10	-11	-13	-14	-15	-17	-24	-31	-38	-45							
	85	-10	-11	-13	-14	-16	-17	-24	-31	-39								
	90	-10	-12	-13	-15	-16	-17	-25	-32	-39								
	95	-10	-12	-13	-15	-16	-18	-25	-32	-39								
	100	-11	-12	-14	-15	-16	-18	-25	-32	-40								
	105	-11	-12	-14	-15	-17	-18	-25	-33	-40					-76			
	110	-11	-12	-14	-15	-17	-18	-26	-33	-40								
	G (0 to	-10 Low	6	-10 to -3	25 Mode	rate	-25 to - 4	5 Cold		-45 to -	59 Extre	eme .	60 Plus	very Ex	treme		

PROGRAM | Mission, Branding, and Space program

WIND CHILL- Siple e Passel del 1945 reviewed in 2001







Multimedia Architecture Interaction

Adaptive Comfort. Metabolism and Clothing



PROGRAM | Mission, Branding, and Space program

UTCI Equivalent Temperature (°C)





MAILAB Multimedia Architecture

Interaction

Adaptive Comfort. Metabolism and Clothing

MET - The Metabolic Rate



 $1met = 50kcal/hm^2 = 0,05815Kw/hsqm$ 1 kcal = 4.190 J = 1.164 Wh.

1 BTU/h ft2= 5,6783 w/h mq 1 w/h mq= 0,17610904672173 BTU/h ft2 http://www.the-engineering-page.com/conv/u.html

1 BTU = 252 cal 1 BTU = 1,055056 kJ 1 W= 3,412 BTU/h = 1J/s 1 Kcal= 0,00116 Kw/h http://www.convertworld.com

PROGRAM | Mission, Branding, and Space program

	Btu/h-ft ²	Dict [®]
Resting	73.622	24.45
Sleeping	13	0.7
Reclining	15	0.8
Seated, quiet	18	1.0
Standing, relaxed	22	1.2
Walking (on level surface)		
2.9 fps (2 mph)	37	2.0
4.4 fps (3 mph)	48	2.6
5.9 fps (4 mph)	70	3,8
Office Activities		
Reading, seated	18	1.0
Writing	18	1.0
Typing	20	1.1
Filing, seated	22	1.2
Filing, standing	26	1.4
Walking about	31	1.7
Lifting/packing	39	2,1
Driving/Flying		
Car	18 to 37	1.0 to 2.0
Aircraft, routine	22	1.2
Aircraft, instrument landing	33	1.8
Aircraft, combat	44	2.4
Heavy vehicle	59	3.2
Miscellaneous Occupational Activiti	es	
Cooking	29 to 37	1.6 to 2.0
Housecleaning	37 to 63	2.0 to 3.4
Seated, heavy limb movement	41	2.2
Machine work		
sawing (table saw)	33	1.8
light (electrical industry)	37 to 44	2.0 to 2.4
heavy	74	4.0
Handling 110 lb bags	74	4.0
Pick and shovel work	74 to 88	4.0 to 4.8
Miscellaneous Leisure Activities	C Stormer	
Dancing, social	44 to 81	2.4 to 4.4
Calisthenics/exercise	55 to 74	3.0 to 4.0
Tennis, singles	66 to 74	3.6 to 4.0
Basketball	90 to 140	5.0 to 7.6
Wrestling, competitive	130 to 160	7.0 to 8.7

Sources: Compiled from various sources. For additional information, see Buskirk (1960), Passmore and Durnin (1967), and Webb (1964).

*1 met = 18.4 Btu/h ft?





PROGRAM | Mission, Branding, and Space program

Adaptive Comfort. Metabolism and Clothing

MET - The Metabolic Rate

Sitting Activity Met = 1 = 50kcal/hsqm=0,05815Kw/hsqm



100 watt/h

Average body surface Male= 2 mq Female= 1,75

100 watt/h

Architecture

nteractio

PROGRAM | Mission, Branding, and Space program

Adaptive Comfort. Metabolism and Clothing

MET - The Metabolic Rate



Converting the excess heat generated by the Stockholm Central Station's 2500 daily users to hot water and pump it to the nearby Kungsbrohuset office block.









PROGRAM | Mission, Branding, and Space program

Adaptive Comfort. Metabolism and Clothing

CLO - The Clothing Rate







MAILAB Multimedia Architecture

Interactio

Adaptive Comfort. Metabolism and Clothing



Comfort Temperature





Adaptive Comfort. Methods

ESTIMATING ACCETABLE INDOOR THERMAL COMFORT OVER STANDARDIZED VALUES USING AULICIEMS METHOD (1981)

Tc=13,5+0,54To

Month	Avg Temp (To)(°C)	Comfort Temp (Tc) (°C)
January	5.3	16.4
February	3.4	15.3
March	8	17.8
April	8.1	17.9
May	11.2	19.5
June	15.8	22
July	19.7	24.1
August	16.9	22.6
September	13.1	20.6
October	9.9	18.8
November	10.4	19.1
December	6.7	17.1

Temperature needed to achieve comfort



MAILAB

Multimedia

Architecture

Interaction

PROGRAM | Mission, Branding, and Space program

Standard code

 $20^{\circ}C \pm 2^{\circ}C^{\circ}$

Auliciems A. et al, 2007, Thermal Comfort [pdf] Passive and Low Energy Architecture International in association with the Department of Architecture, The University of Queensland Brisbane



Tc = comfort temperature To = outdoor temperature

https://edplondon.weebly.com/comfort/estimating-the-comfort-temperature-using-the-equationtc135054to-where-tc-is-the-comfort-temperature-and-to-is-the-outdoor-temperature







MAILAB Multimedia Architecture Interaction

Adaptive Comfort. Methods

ESTIMATING ACCETABLE INDOOR THERMAL COMFORT OVER STANDARDIZED VALUES USING AULICIEMS METHOD (1981)



PROGRAM | Mission, Branding, and Space program

https://edplondon.weebly.com/comfort/estimating-the-comfort-temperature-using-the-equationtc135054to-where-tc-is-the-comfort-temperature-and-to-is-the-outdoor-temperature

Adaptive Comfort. Methods

OUTDOOR COMFORT METHODS

Universal Thermal Comfort Index (UTCI)

UTCI follows the concept of an equivalent temperature. This method summarises the interaction of environmental agents such as: temperature, wind speed, and humidity, and radiation (long-wave and short-wave radiant heat fluxes).

Physiological Equivalent Temperature (**PET**)

PET is one of the most commonly used indices for measuring heat stress in outdoor spaces. It is the output of Munich Energy Balance Model for Individuals (MEM

INDOOR COMFORT METHODS

Adaptive Method (AM)

proposed for spaces where occupants can control their thermal environment by means of clothing, operable windows, fans, personal heathers, and sun shaders

• Predicted Mean Vote (**PMV**)

Proposed by Fanger for controlled chamber under steady state conditions. It uses four environmental parameters (including dry temperature, radiation temperature, wind speed, and relative humidity) and two human parameters (clothing insulation and metabolic rate). It's range goes from -5 to +5. It's Benchmark should be around 0

• Predicted Percentage Dissatisfied (**PPD**)

It's based on PMV and its value ranges goes from 0 to 100. It's Benchmark should be <20%

MAILAB

Multimedia

Architecture

Interaction

PROGRAM | Mission, Branding, and Space program

Adaptive Comfort. Methods

OUTDOOR COMFORT: UNIVERSAL THERMAL COMFORT INDEX

PROGRAM | Mission, Branding, and Space program

Adaptive Comfort. The Psychrometric Chart Tool

Thermal comfort and Relative Humidity

Barometric Pressure 101.325 kPa (Sea level) based on data from

Enthaloy at Sat

Psychrometric Chart

Loweristhe, emperature loweristhe available quantity of water

5

-5

0_

-10

20

15

10

5

Psychrometric Chart

SI (metric) units Barometric Pressure 101.325 kPa (Sea level) based on data from Carrier Corporation Cat. No. 794-001, dated 1975

\$0

10

10

0

5

0_

-10

20

15

80

SI (metric) units Barometric Pressure 101.325 kPa (Sea level) based on data from

Dry Bulb Temperature (°C)

Barometric Pressure 101.325 kPa (Sea level) based on data from

NOMOGRAM INTEGRATING EFFECTIVE TEMPERATURE

	25%	30%	35%	40%	45%	50%	55%	60%	65%	70%	75%	80%	85%	90%	95%	100%
42°	48	50	52	55	57	59	62	64	66	68	71	73	75	77	80	82
41°	46	48	51	53	55	\$7	59	61	64		68	70	72	74	76	79
40°	45	47	49	51	53	85	57	59	61	63	65	67	69	71	73	75
39°	43	45	47	49	51	53	55	57	59	61	63	65	86	68	78	72
38°	42	44	45	47	49	51	53	55	56	58	60	62	84	66	67	69
37°	40	42	44	45	47	49	51	52	54			59	61	63	65	86
36°	39	40	42	44	45	47	49	50	52	54	55	57	59	60	62	63
35°	37	39	40	42	44	45	47	48	50	51	53	54		58	59	61
34°	36	37	39	40	42	43	45	46	48	49	51	52	54	55	57	
33°	34	36	37	39	40	41	43	44	46	47	48	50	51	53	54	55
32°	33	34	36	37	38	40	41	42	44	45	46	48	49	50	52	53
31°	32	33	34	35	37	38	39	40	42	43	44	45	47	48	49	50
30°	30	32	33	34	35	36	37	39	40	41	42	43	45	46	47	48
29°	29	30	31	32	33	35	36	37	38	39	40	41	42	43	45	46
28°	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43
27°	27	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41
26°	26	26	27	28	29	30	31	32	33	34	34	35	36	37	38	39
25°	25	25	26	27	27	28	29	30	31	32	33	34	34	35	36	37
24°	24	24	24	25	26	27	28	28	29	30	31	32	33	33	34	35
23°	23	23	23	24	25	25	26	27	28	28	29	30	31	32	32	33
22°	22	22	22	22	23	24	25	25	26	27	27	28	29	30	30	31

Fino a 29 C° Nessun disagio

Da 30 a 34 C° Sensazione di disagio

Da 35 a 39 C° Intenso disagio. Prudenza: limitare le attività fisiche più pesanti

Da 40 a 45 C° Forte sensazione di malessere. Pericolo: evitare gli sforzi

Da 46 a 53 C^o Pericolo grave: interrompere tutte le attività fisiche

Pericolo di morte: colpo di calore imminente

Fig. 8-8. Nomogram for the "new," effective temperature (ET*), including data points for US Army heat deaths provided by Hardy. ashrae: American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc; clo: unit of clothing insulation, 1 clo = 0.155 m² K/W; MET: unit of metabolism, 1 MET = 58.15 W/m². RH: relative humidity. Illustration: Adapted with permission from ASHRAE. Copyright 2005 © American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc (www.ashrae.org). Reprinted with permission from the 2005 ASHRAE Handbook-Fundamentals. (This text may not be copied nor distributed in either paper or digital form without ASHRAE's permission.) Data source: Hardy JD. Thermal comfort and health. ASHRAE J. 1971;13:43.

Multimedia Architecture Interaction

Adaptive Comfort. The Psychrometric Chart Tool

EFFECTIVE TEMPERATURE & THERMAL COMFORT ZONE

MAILAB Multimedia Architecture

Adaptive Comfort. Computational Tool

CBE THERMAL COMFORT TOOL >to access the tool: http://comfort.cbe.berkeley.edu/EN ENTER FOR THE BUILT ENVIRONMENT

INDOOR COMFORT METHODS

Adaptive Method (AM)

proposed for spaces where occupants can control their thermal environment by means of clothing, operable windows, fans, personal heathers, and sun shaders

Predicted Mean Vote (PMV)

Proposed by Fanger for controlled chamber under steady state conditions. It uses four environmental parameters (including dry temperature, radiation temperature, wind speed, and relative humidity) and two human parameters (clothing insulation and metabolic rate). It's range goes from -5 to +5. It's Benchmark should be around 0

Predicted Percentage Dissatisfied (PPD)

It's based on PMV and its value ranges goes from 0 to 100. It's Benchmark should be <20%

PROGRAM | Mission, Branding, and Space program

INDOOR COMFORT

Adaptive Comfort. Hygrothermic Computational Tool INDOOR COMFORT

Select method:

22.4

13.1

Air speed

Local

discomfort

temperature

MAILAB Multimedia Architecture Interaction

PROGRAM | Mission, Branding, and Space program

Adaptive Comfort. Hygrothermic Computational Tool

CBE Thermal Comfort Tool ASHRAE-55 EN-15251 Compare Ranges Upload Adaptive method Complies with ASHRAE Standard 55-2017 80% acceptability limits Operative temperature: 18.4 to 25.4°C Operative temperature Ĵ° € Comfortable → Status Use operative temperature 90% acceptability limits Operative temperature: 19.4 to 24.4°C Prevailing mean outdoor → Status Comfortable ℃ ℃ Adaptive chart 34 0.3 m/s (59 fpm) LEED documentation 32 SolarCa 30 pressure 28 0° e 26 24 \odot 22 e ad 20 14 10 12 30 14 20 22 32 16 18 24 26 28 Prevailing Mean Outdoor Temperature [°C] NOTE: Method is applicable only for occupant-controlled naturally conditioned

spaces that meet all of the following criteria: (a) There is no mechanical cooling system installed. No heating system is in operation; (b) Metabolic rates ranging from 1.0 to 1.3 met; and (c) Occupants are free to adapt their clothing to the indoor and/or outdoor thermal conditions within a range at least as wide as 0.5-1.0 clo.

INDOOR THERMAL COMFORT USING ADAPTIVE METHOD (ASHRAE 55-2017)

NOTE: Method is applicable only for occupant-controlled naturally conditioned spaces that meet all of the following criteria: (a) There is no mechanical cooling system installed. No heating system is in operation; (b) Metabolic rates ranging from 1.0 to 1.3 met; and (c) Occupants are free to adapt their clothing to the indoor and/or outdoor thermal conditions within a range at least as wide as 0.5-1.0 clo.

PROGRAM | Mission, Branding, and Space program

Adaptive Comfort. Hygrothermic Computational Tool

INDOOR THERMAL COMFORT USING ADAPTIVE METHOD (EN-15251)

NOTE: Method is applicable only for buildings without mechanical cooling systems and where there is easy access to operable windows and occupants may freely adapt their clothing to the indoor and/or outdoor thermal conditions. The criteria for the spaces are the following: (a) There is no mechanical cooling or heating system in operation; (b) Metabolic rates ranging from 1.0 to 1.3 met; (c) Occupants are allowed to freely adapt their clothing insulation.

Through this tool is possible to visualize the range of comfort when people are able to adapt their clothes, metabolism and... windows

PROGRAM | Mission, Branding, and Space program

Adaptive Comfort. Hygrothermic Computational Tool

CBE Thermal Comfort Tool 0. Set ASHRAE-55. Set EN-15251 for EU context 1. Set PMV method Select method: PMV method Air temperature 5. Adjust Air & Main radiant temperature (same value) 25 Use operative temperature unitll the red dot is on the middle of the graph. Mean radiant temperature That is the raccomended value for that functional °C 25 activity and space Air speed m/s 0.1 Local air speed control 2. Set Air speed 0.1 Humidity % 50 Relative humidity 3. Set Humidity 40% * Metabolic rate 1.1 Typing: 1.1 4. Set Methabolic rate & Clothing Rate according to the Clothing level analyzed activity 🗘 clo 0.5 Typical summer indoor Create custom ensemble 2 Dynamic predictive clothing * Alternatives temperatures values for each functional B LEED documentation values can be checked modifying Humidity (30-55%) Globe Local SolarCal temp discomfort pressure

<u>...and compare results with temperature</u> <u>values established by national codes</u>

INDOOR THERMAL COMFORT USING ADAPTIVE METHOD (ASHRAE 55-2017)

Multimedia Architecture Interaction

Adaptive Comfort. Thermal Environmental Cluster

MAILAB

Multimedia

Architecture

Interaction

THERMAL THERMAL ZONE 1 ZONE 2 ristorante 240 m² camere 350 m² aree comuni 250 m² ingresso 70 m² lounge Bar 120 m²

servizi 35 m²

 $+/-645 \text{ m}^2$ $+/-470 m^{2}$

servizi

50 m²

RANGE MET zone 1

zone 3

0 40 40 40

RANGE CLO

